

SPECIFICATIONS

GIRTON PERSONNEL DECONTAMINATION SHOWER MODEL PW87

Specification No. **PW87**

For Company Name

1. DESCRIPTION

Personnel decontamination showers shall remove all detectable contaminate from a single, suited occupant. Showers shall be safe reliable, and capable of repeating shower cycles several times
All showers shall be operationally tested prior to shipment.

2. REGULATIONS, CODES AND STANDARDS

All engineering, design, manufacture and testing conforms to all applicable sections of the latest edition of the following codes, standards and specifications in effect at the time of order:

ASME-BPE - American Society of Mechanical Engineers

ANSI - American National Standard Institute

ASTM - American Society for Testing and Materials

OSHA - Occupation Safety and Health Administration

NEMA - National Electrical Manufacturers Associates

NEC - National Electrical Code

cGMP - Current Good Manufacturing Practices (CFR Title 21 parts 210 and 211)

NFPA - National Fire Protection Association

UL508A – Industrial Control Panels

3. DIMENSIONS AND WEIGHT

- 3.1. Overall Height: 113" Add 42" with dryer option
- 3.2. Overall Width: 52"
- 3.3. Overall Depth: 52"
- 3.4. Operational Weight: 1,500 lbs.

4. CONSTRUCTION

4.1. Material Type and Finish:

- 4.1.1. **Washer Cabinet:** 14 gauge, T-304 T-316L stainless steel
Interior Finish: mill finish (2B) 35Ra or better 15Ra 8.5Ra
Exterior Finish: 35Ra or better
- 4.1.2. **Insulation Jacket:** 18 gauge, T-304 stainless steel,
Exterior Finish: 35Ra or better

- 4.1.3. **Door:** T-304 T-316L stainless steel
Interior Finish: mill finish (2B) 35Ra or better 15Ra 8.5Ra
Exterior Finish: 35Ra or better
- 4.1.4. **Steam and Condensate Piping:**
Interior on Washer: stainless steel T-304 T-316L schedule 10 pipe
Exterior on Washer: stainless steel T-304 schedule 40 pipe
- 4.1.5. **Compressed Air:**
Tubing Poly-flo T-304 stainless steel.
- 4.1.6. **Potable Water Supply Ball Valves:** T-304 stainless steel
Steam Supply Ball Valves: T-304 stainless steel
- 4.1.7. **Header and Piping:** T-316L stainless steel
Interior Finish: 35Ra or better Electro-polished to 15 Ra finish 20Ra
Exterior Finish: 35Ra or better
- 4.1.8. **Tri-Clamp Clamps:** T-304 stainless steel
- 4.1.9. **Fasteners:** T-304 stainless steel
- 4.2. **Unit Design:**
The equipment is designed to be shipped and installed as a **single unit**. Some parts may be removed prior to shipping (i.e., pumps) to decrease the possibility of damages during shipping. The maximum crate size will be approximately _____" x _____" x _____" with an estimated weight of _____lbs.
- Bolted and gasketed** construction allows the washer to be taken down prior to crating. There will be approximately _____ # separate pieces and the largest piece will be approximately _____" x _____" x _____" with an estimated weight of _____lbs. A minimum clearance of _____" x _____" is necessary for access into the building. It is strongly recommended Girton Manufacturing Co., Inc. be contracted to re-assemble or supervise the re-assembly of the equipment due to the custom nature of the equipment.
- 4.3. All **internal corners** have a minimum 5/16" radius.
- 4.4. All visible **welds** on the exterior of the washing compartment are thoroughly cleaned. All welds on the interior of the washing compartment are ground and polished.
- 4.5. The **cabinet interior** is constructed to permit free draining and designed not to retain any of the process solutions.
- 4.6. The **washer drains** by gravity.
- 4.7. All four sides and top are **insulated** with rigid foam and covered with a full jacket. This insulation package greatly reduces radiated heat loss from the washer making it more economical to operate and affords more comfort for the operators.
- 4.8. The washer shall be provided with **hinged doors**.
The door shall be double walled and insulated with rigid foam insulation. The door shall be baffled and gasketed against water leakage from the wash chamber. Door gaskets shall be closed cell silicone. The door shall be provided with a 16" x 18" vapor-proof heat tempered glass as a viewing window. The window is sealed against water leakage by means of a silicone gasket.
- 4.9. **Potable water supply ball valves** are threaded connections.
Steam supply ball valves are threaded connections.
- 4.10. All **ancillary valves and equipment are positioned** on the washing machine top, rear and the side of the washer.
- 4.11. **Headers** - Shall consist of stationary stainless steel T-316L stationary headers, employing properly spaced, wide angle stainless steel machined jets shall direct the process solutions from the top, and both sides and bottom assuring 360° continuous coverage of the wash chamber.
- 4.12. **Tri-clamp connection** use **EPDM gaskets** and are connected by means of heavy-duty clamps with wing nuts.

- 4.13. **Seals, gaskets, and bearings** are compatible with the temperatures and concentrations of cleaning agents to be used. Customer will supply information on chemicals to be used.
- 4.14. **A compressed air system** is supplied with a filter regulator.
- 4.15. The washer is piped and wired for **single service connection** for each utility requirement.

5. CONTROLS AND OPERATION

- 5.1. The control system incorporates an **Allen Bradley Compact Logix ®PLC**. This provides 512K of memory with Ethernet communication ability. The processor is aware of and controls all items on the washer. I/O cards are selected to match the control voltage. An isolated relay card is used to control high current draw items or items not operable at the control voltage. Analog cards are set to accept 4 - 20 mA inputs, unless otherwise noted.
- 5.2. The operator-machine consists of an **Allen Bradley Color Panelview Plus 6 - 600**, which incorporates a touch screen for operator control. This allows the user with proper password level to access all parameters of a wash recipe. All alarms are shown on the display, as well as announced audibly.
- 5.3. Girton control panels will be designed, manufactured and labeled as per **UL508A**.
- 5.4. The washer is provided with the ability to use a printer to record operation reports. The customer should mount the printer close to the washer. Communication to the printer will be determined during detailed design and outlined in the functional specification. The report contains the following data: machine identification, operator, date and time, step name with time, temperature (min-max), etc.
- 5.5. Water tight **start / stop** buttons shall be provided on the inside of the chamber to allow the operator to initiate the treatment cycle.
- 5.6. A **typical treatment cycle** is defined as follows:
 - Pre-Rinse
 - Wash
 - Rinse
 - Air Blow-Off (optional)
- 5.7. A total of **20 programs** can be stored in the PLC. Each program can be altered or developed from the OIT. Access to change or develop the programs is password protected.
- 5.8. Girton provides four levels of **password protection** to the control system:
 - Operator Level
 - Maintenance Level
 - Engineering Level
 - Administration
- 5.9. Girton's control system provides the ability to **alarm on abnormal conditions**. The washer has alarms based on each I/O point failure. This provides a comprehensive way of determining a device failure or process deviation. In general, all analog inputs to the system will have low and high alarm points settable by the customer. Also, all safety devices, such as door switches or emergency stop buttons, have alarms associated with them.
- 5.10. The washer is equipped with **Emergency Stop** switches located at critical points on the machine. All doors are equipped with limit switches wired directly to the output voltage. Opening any door will disconnect voltage from output cards thereby shutting down the system. These switches are also wired as inputs to the PLC so that an alarm may be generated. All services are equipped with fail-closed-valves.
- 5.11. **Noise level** as measured from 3 ft. from the washer will be a **maximum of 85 dBa**.

6. DOCUMENTATION

- 6.1. **1 Hard copy and 1 electronic copy of Girton Documentation Package**. Validation requirements and considerations are playing an increasingly major role in the purchase of new equipment or systems. Validation requires documented evidence that the equipment or system will reliably perform in a manner consistent with the original design specifications. Generation of this documentation needs to be considered at the inception of the project and implemented throughout the design and manufacturing stages of the equipment. In most instances, the equipment vendor is the most qualified party to generate the majority of the required documentation.

The documentation provided by Girton Manufacturing Co., Inc. is designed to be a complete package including all data and checklists necessary to qualify the installation and operation of the equipment and/or system. All equipment built by Girton is completely factory assembled and tested. The documentation is used to perform Factory Acceptance Testing; witnessed and approved by the customer. All tests necessary for Installation and Operation Qualification of the equipment are performed on the equipment prior to its arrival on the job-site. Any modifications or additions required to qualify the equipment can be made at the factory prior to shipment. This index lists all documentation supplied by Girton Manufacturing Co., Inc.

Please reference Project Deliverables, attached to this specification.

7. SERVICE REQUIREMENTS

- 7.1. **Electrical:** 1 phase, 60 cycle, 120 volt.
- 7.2. **Hot Water:** 80°F. Recommended minimum rate of flow of 25 gallons per minute. 1" tri-clamp connection to the machine.
- 7.3. **Steam:** 40 to 80 PSI. 1-1/2" NPT connection to the machine (for most efficient operations, 60 PSI is recommended). 200-lb./hr. requirement.
- 7.4. **Condensate:** 3/4" NPT.
- 7.5. **Drain:** 3" Pipe size from the machine to the drain.
- 7.6. **Ventilation:** 6" diameter vent collar is provided for connection to ventilating system. 100 CFM minimum removal required. Connection should be installed inside of vent collar to prevent leakage.
- 7.7. **Compressed Air:** 1/4" NPT connection, 90-PSI minimum, 5 CFM.

8. WARRANTY

- 8.1. Girton Manufacturing Co., Inc. warrants equipment of original manufacture against defect in workmanship and material for a period of one year from date of shipment. Provided; however, the equipment has been operated under normal working conditions for such said equipment, that it has been properly serviced and cared for, and that no adjustments have been made by unauthorized personnel that could adversely affect the operation or life of the equipment.

Girton Manufacturing Co., Inc. will replace or repair defective merchandise at its plant, FOB Millville, PA, if after inspection; the equipment or components that Girton manufactured are defective. Girton Manufacturing Co., Inc. extends to its customers on all purchased components parts, the warranty of the supplier of such said parts.

No expense, liability, or responsibility will be assumed by Girton for repairs outside Girton's factory, without written authority from Girton Manufacturing Co., Inc.

The foregoing warranty excludes all other warranties, guaranties, and/or representations; whether expressed, implies, or oral, INCLUDING, BUT NOT LIMITED TO, ALL CONDITIONS AND EXCLUSIONS OF IMPLIED WARRANTY OF MERCHANTABILITY AND OR FITNESS FOR THE PURPOSE, and the warrantor's liability for any direct damage arising from a legally proven breach of the warranty hereby extended is limited to the customer's invoice cost of the goods warranted.

- 8.2. DISCLAIMER OF CONSEQUENTIAL DAMAGES LIABILITY - Girton Manufacturing Co., Inc. shall not be liable for consequential damages of any kind, including incidental labor or other costs.

9. CANCELLATION

- 9.1. Any order on which work had been started may be cancelled only by consent of Girton Manufacturing Co., Inc. and by agreement on the part of the purchaser to cover whatever cost has been incurred, if any, to the date of the cancellation, including engineering, administrative, material purchases, labor, and overhead expended.

10. CUSTOMER TO WITNESS PRELIMINARY FACTORY ACCEPTANCE TEST (FAT)

- 10.1. Customer may witness preliminary testing performed at Girton Manufacturing Co., Inc. prior to shipment to customer's facility.

Customer will supply adequate samples of the items being washed. If customer specifies a particular chemical to be used, they shall supply it, complete with a MSDS Report. Customer shall be responsible for disposal or removal of excess chemical from premises.

- 10.2. **Factory Acceptance Test (FAT)** – Girton Manufacturing Co., Inc. will provide the necessary personnel for a maximum of 3 days to assist with the Factory Acceptance Test (FAT). The Girton Factory Technicians will work with the customer's personnel in verifying the washer is built and operates according to the FAT documentation.

11. DOCUMENTS

- 11.1. **Approval Documents** will be provided to the Customer in ___days weeks after receipt of order. Production work will not be initiated until these drawings are returned to Girton Manufacturing Co., Inc. with the appropriate signatures of the customer.

12. INSTALLATION

- 12.1. Installation will be **done by others**.

Supervision of installation by Girtons - Girton Manufacturing Co., Inc. will provide a technician for _____ (# of days) who will work with the customer's in-house personnel or with an outside contractor. The technician(s) will provide instructions for all phases of re-assembly including moving the equipment, leveling, re-assembly, and connection to utilities for an additional fee.

Set-in-place installation by Girtons -

Girton Manufacturing Co., Inc. will provide the necessary non-union labor to re-assemble the equipment and make it ready for utility connections at the customer's site. The customer will be responsible for receiving the equipment, unloading and moving it to the area where it is to be installed prior to Girton's arrival and for connecting the utilities.

Girton Manufacturing Co., Inc. will provide the necessary union labor to re-assemble the equipment and make it ready for utility connections at the customer's site. The customer will be responsible for receiving the equipment, unloading and moving it to the area where it is to be installed prior to Girton's arrival and for connecting the utilities.

Complete installation by Girtons

Girton Manufacturing Co., Inc. will provide the necessary non-union labor and material to perform a complete installation of the equipment. This includes receiving the equipment at the customer's site, unloading, uncrating, move in place, re-assembly and connection to existing utilities. The utilities must be within 4 feet from the equipment.

Girton Manufacturing Co., Inc. will provide the necessary union labor and material to perform a complete installation of the equipment. This includes receiving the equipment at the customer's site, unloading, uncrating, move in place, re-assembly and connection to existing utilities. The utilities must be within 4 feet from the equipment.

13. TERMS AND CONDITIONS

- 13.1. Payment Terms:
Please consult factory.
- 13.2. The 6% PA sales tax will be assessed on all sales. If you believe the products covered by this proposal are exempt from this tax, please send to Girton Manufacturing Co., Inc. your PA sales tax exemption certificate.

14. SHIPPING

- 14.1. Freight terms:
Collect
Prepaid by customer and add to Invoice
Third Party Billing
- 14.2. Shipment will be provided by transportation arranged by Girton Manufacturing Co., Inc.
customer.

- 14.3. Shipment from Millville, PA ___ to ___ weeks, after receipt of Approved Drawings by Girton Manufacturing Co., Inc.

15. TOTAL COST PER SPECIFICATION, CONSULT FACTORY

16. OPTIONS

- 16.1. The Human Machine Interface (HMI), mounted on the washer, consists of a PLC based display, which will be programmed using RSView SE software, which incorporates a touch screen for operator control and monitoring. This allows the user with proper password level to access all parameters of a wash recipe. All alarms are shown on the display, as well as announced audibly. Use of this system complies with CFR21 Part 11.

- 16.2. **Pass through operation** is accomplished with two (2) **hinged doors**.

Each door is double walled and insulated with rigid foam insulation. The doors are baffled and gasketed against water leakage from the wash chamber. Door gaskets are closed cell silicone. The doors are provided with a 16" x 18" vapor-proof heat tempered glass as a viewing window. The window is sealed against water leakage by means of a silicone gasket. A **door safety switch** is provided on each door. The switch shall stop the cycle and shut down the washer operation in the event that either door is opened.

- 16.3. **Door interlocks** prevent the load and unload door from being opened simultaneously. This system consists of two pneumatic air cylinders, two control valves all controlled by the washer controller.

Operation shall be as follows:

Load door open - unload door is locked.

Unload door open - load door is locked.

Washer operating or idle - both doors are unlocked.

- 16.4. **T-316L construction** on all wetted surfaces with the exception of distribution hoses.

- 16.5. **Interior finish** to be a 35Ra or better finish.

- 16.6. **Air blow-off** - The dryer consists of a recirculated hot air system utilizing steam coils electric heating elements and a high volume blower to circulate hot air over the items to be dried. A small amount of room air is drawn into the system to aid in maintaining proper humidity levels for efficient drying. The controller controls the drying cycle and temperature.

16.6.1. Heating surface is fabricated of copper tubes with aluminum fins. Blower is fabricated of painted steel.

16.6.2. Stainless steel air stream of T-304 T-316L. Blower is fabricated of T-304 T-316L stainless steel. A HEPA filter is provided on discharge of blower.

- 16.7. A **light fixture** mounted on the exterior of the unit illuminates the wash chamber during operation.

- 16.8. All **compressed air lines** are T-304 stainless steel with Swagelok compression split ferrule type fittings.

- 16.9. **Automatic detergent dispensing system** is provided with the control system. One (1) diaphragm pump is used to charge the wash solution with the desired reagent. The customer sets the amount of time that each dispenser will run for the wash cycle.

- 16.10. For each reagent reservoir, Girton supplies a **level monitor**. The monitor will consist of an ultrasonic sensor that will switch a PLC input when the reagent reaches the specified level. The control can then either trigger an alarm or a status message based on the input. The sensor has threads allowing it to be mounted into the lid of the customer's detergent reservoir.

- 16.11. A **remote mounted dot matrix printer** will be provided so that a printed record of each cycle can be obtained.

- 16.12. **Fused disconnect switch** is supplied and located in the main electrical enclosure to cut power to the entire unit. The system is designed so if the disconnect is in the "ON" position the electrical enclosure is not be able to be opened.

- 16.13. The washer is specified to be in a **Class I Division 2 Group D area**. All wiring, conduit, instruments, and other devices conform to the NEC and NFPA regulations for the class and division of the washer. If required, purged enclosures will be provided as well as explosion resistant conduit.
- 16.14. All **conduit** on the machine are PVC coated rigid. Fittings and conduits are PVC coated as well. Liquid tight flexible conduit is used to connect the washer's devices. Lengths of flexible conduit do not exceed 3 feet. All marks on conduit are painted with PVC paint. All conduit installation meets the current NEC requirements.
- 16.15. All controls are rated at **24VDC**, if possible. Items not able to operate at 24VDC have a control relay that will provide contacts usable at 120VAC.
- 16.16. An **exhaust fan**, wired and mounted on machine, including manual damper, is provided. The fan will exhaust 300 CFM to the ventilating system or to the outside. A 6" diameter vent collar is also provided. The connection is installed inside of vent collar to prevent leakage.
- 16.16.1. Epoxy painted air-steam.
- 16.16.2. T-304 T-316L stainless steel air-steam.
- 16.17. **Additional copies of our Documentation Package** (reference item # _____ of this specification) may be purchased.
- 16.18. **Optional Documentation:**
- 16.18.1. Surface Finish Map and Certificate of Compliance
- 16.18.2. Slope Map of Process Contact Tubing and Certificate of Compliance
- 16.18.3. Video Weld Logs
- 16.18.4. Sound Level Certificate of Conformance
- 16.19. **Supervision of installation (YSOFI)** – Girton Manufacturing Co, Inc. will provide ONE Qualified Technician for ___ on-site days to Supervise and Direct Customer Personnel, Contractors or Subcontractors in all phases of Installation. This includes oversight of Uncrating and Moving the Equipment into a prepared⁽¹⁾ Wash Room, Leveling and Reassembly, Utility⁽²⁾ and Additional Support Systems⁽³⁾ Connections. Supervision of Unloading the Shipping Truck will be performed *only if* delivery occurs during the scheduled timeframe.
- Supervision of Installation (SofI) does **not** include Sub-Contracting, Equipment or Tools or Tool Rental, Dumpsters and/or Trash Disposal, Multiple Trips from our Factory (except at our discretion and as deemed necessary by our Technical Service Manager), Additional Site Preparation, Materials for Floor Protection, Integration Materials or Fabrication (other than Modular Walls, Fascia Panels, and items purchased from Girton Mfg. as an option), Equipment Start Up, Training of Personnel or Assisting with SAT or Validation Documentation.
- The Customer will be responsible for all facets of installation not specifically included above. Equipment Start Up, Training of Personnel, Assisting with SAT or Validation Documentation may be purchased from Girton separately.
- A Field Report will be submitted to the Customer within one week of completion of the installation.
- Supervision of Installation is a quoted option and valid as part of the original equipment order. Service ordered after the original equipment order date will require a re-quote. Travel expenses are included in the first day billing. Additional contiguous days may be purchased for a flat fee of \$_____.00 per day, but should be purchased prior to the first on-site day, if possible. This information is based on non-union labor. Special provisions and prices apply when union labor and/or prevailing wages are required. Contact your Sales Rep for further details.
- 16.20. **Set-in-place Installation (YSIP)** - Girton Manufacturing Co, Inc. will provide Qualified Technicians for ___ on-site days to Unload and Uncrate, Move the equipment to a prepared⁽¹⁾ location, Reassemble and Level the Equipment. Girton Manufacturing Co, Inc. will provide all Personnel, Material, Tools and Equipment to perform the task, including Fork Trucks, Dumpsters, Welders, Hand Tools, Floor Protection and Trash Elimination.
- Set-In-Place Installation (SIP) does **not** include Utility⁽²⁾ Connections, Connection of Additional Support Systems⁽³⁾, Multiple Trips from our Factory (except at our discretion and as deemed necessary by our Technical Service Manager), Additional Site Preparation, Integration Materials or

Fabrication (other than Modular Walls, Fascia Panels, etc., purchased from Girton Mfg. as an option), Equipment Start Up, Training of Personnel or Assisting with SAT or Validation Documentation.

The Customer will be responsible for all facets of installation not specifically included above. Equipment Start Up, Training of Personnel, Assisting with SAT or Validation Documentation may be purchased from Girton separately.

A Field Report will be submitted to the Customer within one week of completion of the installation.

Set-In-Place Installation is a quoted option and valid as part of the original equipment order. Service ordered after the original equipment order date will require a re-quote. Travel expenses are included in the first day billing. Additional contiguous days may be purchased for a flat fee of \$____.00 per 8 Hr. man-day, but should be purchased prior to the first on-site day, if possible.

This information is based on non-union labor. Special provisions and prices apply when union labor and/or prevailing wages are required. Contact your Sales Rep for further details.

- 16.21. **Complete Installation (YINSTALL)** - Girton Manufacturing Co, Inc. will provide Qualified Technicians for ___ on-site days to Unload, Uncrate, Move the equipment to a prepared⁽¹⁾ location, Reassemble, Level the Equipment and Connect Utilities⁽²⁾ to **existing stubs** within 6' of the machine. Girton Manufacturing Co, Inc. will provide all Personnel, Material, Tools and Equipment to perform the task, including Fork Trucks, Dumpsters, Welders, Hand Tools, Floor Protection and Trash Elimination. Test and Demonstration (see below) is part of this option. If this cannot be completed contiguously (due to unavailable utilities, Customer personnel availability, etc.), a return trip must be scheduled and additional travel expenses will apply.

Complete Installation (CI) does **not** include Multiple Trips from our Factory (except at our discretion and as deemed necessary by our Manager), Additional Site Preparation, Connection of Additional Support Systems⁽³⁾, Integration Materials or Fabrication (other than Modular Walls, Fascia Panels, etc., purchased from Girton Mfg. as an option), Equipment Start Up, Training of Personnel or Assisting with SAT or Validation Documentation.

The Customer will be responsible for all facets of installation not specifically included above. Equipment Start Up, Training of Personnel, Assisting with SAT or Validation Documentation may be purchased from Girton separately.

A Field Report will be submitted to the Customer within one week of completion of the installation.

Complete Installation is a quoted option and valid as part of the original equipment order. Service ordered after the original equipment order date will require a re-quote. Travel expenses are included in the first day billing. Additional contiguous days may be purchased for a flat fee of \$____.00 per 8 Hr. man-day, but should be purchased prior to the first on-site day, if possible.

This information is based on non-union labor. Special provisions and prices apply when union labor and/or prevailing wages are required. Contact your Sales Rep for further details.

- 16.22. **Test and Demonstration (YTD)** - Girton Manufacturing Co, Inc. will provide ONE Qualified Technician for ___ on-site days to perform Start Up Testing, such as verifying utility connections and capacities, electrical supply voltage and amperage, motor rotations, completeness of assembly, missing components, etc., on fully installed⁽⁴⁾ equipment. The Technician will make normal *equipment* adjustments and test operation against factory standards. Upon completion of satisfactory testing, the Technician will demonstrate all phases of the use and operation of the equipment to any interested parties, provided sufficient time is allotted. We recommend that three to four hours be dedicated for effective demonstration. We highly recommend that at least one User of each level of access (Operator, Maintenance, Supervisor/Engineering, Administrative) be present for the demonstration. *Demonstration must not be confused with training; it is NOT a substitute for a complete and formal training session*, 'Demonstration' is informal, with the Technician covering the highlights of the equipment and operation and hazard awareness, and answering questions from interested parties. No handout sheets or post-training testing is given.

Test and Demonstration (T&D) does **not** include mechanical reassembly or completion of wiring or pneumatics (on-skid or otherwise), any function that is normally part of the three Installation options described above, Multiple Trips from our Factory (except at our discretion and as deemed necessary by our Technical Service Manager), Additional Site Preparation, or Assisting with SAT or Validation Documentation.

The Customer will be responsible for all facets of installation not specifically included above. Supervision of Installation, Set in Place Installation, Complete Installation, Training of Personnel, Assisting with SAT or Validation Documentation may be purchased from Girton separately.

A Field Report and a copy of an Attendance Record for the demonstration will be submitted to the Customer within one week from the end of the visit.

Test and Demonstration is a quoted option and valid as part of the original equipment order. Service ordered after the original equipment order date will require a re-quote. Travel expenses are included in the first day billing. Additional contiguous days may be purchased for a flat fee of \$____.00 per 8 Hr. man-day, but should be purchased prior to the first on-site day, if possible.

This information is based on non-union labor. Special provisions and prices apply when union labor and/or prevailing wages are required. Contact your Sales Rep for further details.

- 16.23. **Start Up (YSTART)** - Girton Manufacturing Co, Inc. will provide ONE Qualified Technician for ___ on-site days to perform Start Up Testing, such as verifying utility connections and capacities, electrical supply voltage and amperage, motor rotations, completeness of assembly, missing components, etc., on fully installed⁽⁴⁾ equipment. The Technician will make normal *equipment* adjustments and test operation against factory standards. Start Up does **not** include mechanical reassembly or completion of wiring or pneumatics (on-skid or otherwise), any function that is normally part of the three Installation options described above, Multiple Trips from our Factory (except at our discretion and as deemed necessary by our Technical Service Manager), Additional Site Preparation, or Assisting with SAT or Validation Documentation.

The Customer will be responsible for all facets of installation not specifically included above. Supervision of Installation, Set in Place Installation, Complete Installation, Training of Personnel, Assisting with SAT or Validation Documentation may be purchased from Girton separately.

A Field Report will be submitted to the Customer within one week from the end of the visit.

Start Up is a quoted option and valid as part of the original equipment order. Service ordered after the original equipment order date will require a re-quote. Travel expenses are included in the first day billing. Additional contiguous days may be purchased for a flat fee of \$____.00 per 8 Hr. man-day, but should be purchased prior to the first on-site day, if possible. This information is based on non-union labor. Special provisions and prices apply when union labor and/or prevailing wages are required. Contact your Sales Rep for further details.

- 16.24. **Training (YTR)** - Girton Manufacturing Co, Inc. will provide ONE Qualified Technician for ___ on-site days to formally and thoroughly provide in-depth training to Operators, Maintenance Technicians, Engineering and Administrative Level Personnel. Our Technician will provide a combination of classroom and hands-on field training. A 'Question and Answer' period is encouraged.

16.24.1. **Topics covered are:**

- Hazard Awareness,
- Alarms and the causes of and responses to them,
- Routine Operation,
- Routine Maintenance and Trouble Shooting,
- Set Up, Management and Modification of Recipes (Cycles),
- User Management (Administration).

16.24.2. **Training (TRN)** covers the full range of access and use:

16.24.2.1. **'Operator'** level training covers the daily operation and maintenance, and is the shortest and most basic training.

16.24.2.2. **'Maintenance'** level training includes full Operator training and adds the extensive maintenance diagnostic capabilities available through the HMI, and PM requirements.

16.24.2.3. **'Engineering'** level training will include condensed Operator and Maintenance coverage and adds in-depth Recipe (Cycle) Generation and Management and Recipe and Alarm Set Points. Engineering training is typically restricted to those individuals responsible for control of validated operation.

16.24.2.4. **'Administrator'** level training will have condensed coverage for all levels of use, but will focus primarily on User Administration and Security. At this level, Users Names and Passwords are assigned and Levels of Access Controlled.

Whenever possible, a computer presentation will be shown and pertinent hand out sheets will be distributed. An Attendance Roster and post-training Retention Test will be given and copies will be provided to the Customer.

Training is a quoted option and valid as part of the original equipment order. Service ordered after the original equipment order date will require a re-quote. Travel expenses are included in the first day billing. Additional contiguous days may be purchased for a flat fee of \$_____.00 per day, but should be purchased prior to the first on-site day, if possible. This information is based on non-union labor. Special provisions and prices apply when union labor and/or prevailing wages are required. Contact your Sales Rep for further details.

- 16.25. **Site Acceptance Testing Assistance (YSAT)** - Girton Manufacturing Co, Inc. will provide ONE Qualified Technician for ____ on-site days to assist the Customer's Validation Group(s) with IQ/OQ of fully installed⁽⁴⁾ and running equipment. Girton Mfg. will provide an SAT Template based on the factory test documents and appropriate programming software and test instruments necessary to duplicate the factory tests. Girton Technicians will assist the Customer by providing clarification of test procedures and test results, and through our experience with the PLC and HMI Programming. Sample SAT documents are typically submitted to the Customer for early review. Machine specific documents shall be submitted to the Customer a minimum of two weeks prior to SAT.

Girton Technicians will *not* be responsible for completing partial installations, test document revisions or test completion.

A Field Report will be submitted to the Customer within one week of completion of the SAT.

Site Acceptance Test is a quoted option and valid as part of the original equipment order. Service ordered after the original equipment order date will require a re-quote. Travel expenses are included in the first day billing. Additional contiguous days may be purchased for a flat fee of \$_____.00 per day, but should be purchased prior to the first on-site day, if possible. This information is based on non-union labor. Special provisions and prices apply when union labor and/or prevailing wages are required. Contact your Sales Rep for further details.

16.26. Notes:

- 16.26.1. ⁽¹⁾ "Prepared" site is defined as one at which the building is enclosed, the floor and floor coatings are complete and where Girton personnel can work reasonably unhindered. Electricity (for tools) *must* be available. It is preferred, but not mandatory, that utilities⁽²⁾ are complete and available.
- 16.26.2. ⁽²⁾ "Utilities" are defined as Potable Water (Hot and/or Cold), Steam, Condensate, Ventilation, Electrical, Compressed and/or Instrument Air, and Drains. "Utilities" does *not* include Purified (DI, WRO, WFI, etc.) water sources that require high-purity pipe welding, remote Detergent systems or controls, Chiller/Glycol system piping, Facility Control or Data Systems, networked or otherwise.
- 16.26.3. ⁽³⁾ "Additional Support Systems" are defined as Purified Water (DI, WRO, WFI, etc.), Chiller systems, Detergent Systems, Combustible Liquids or Gas, and Breathing Air. Connection of Additional Support Systems is *always* the responsibility of the Purchaser.
- 16.26.4. ⁽⁴⁾ "Fully Installed" is defined as the equipment being in-place and leveled, and connected to all utilities and additional support systems. Integration with building fabric is not required.

* Excluding Saturdays, Sundays and/or Holidays, unless prearranged.

GIRTON MODEL PW87 VENDOR LIST

<u>COMPONENT</u>	<u>VENDOR</u>
Controller	Allen Bradley
Limit Switches	Allen Bradley
Temperature Transmitter	Weed Instrument
Jets	Spraying Systems
Transformer	Square D
Motor Starters	Allen Bradley
Fuses and Fuse Holder	Cooper Bussmann
Ball Valves - Pneumatic Actuators	Duravalue
Compressed Air Filter Regulator	SMC
Drain Valve	Sharpe
<input type="checkbox"/> Valve (For Steam)	Duravalue
Solenoid Valve (For Pneumatic Actuators)	SMC
<input type="checkbox"/> Condensate Traps	Sarco
Disconnect Switch	Allen Bradley
Emergency Stop Switch	Allen Bradley
 <u>OPTIONS</u>	
Door Interlock	
A. Pneumatic Cylinders	Bimba
B. Pneumatic Control Valves	SMC
Drying System	
A. Blower	Girton
B. Steam Coils	Super Radiator Coil
C. Steam Control Valve	Duravalue
D. Condensate Trap	Sarco
Dryer HEPA Filter	Air Guard
Differential Pressure Switch	Dwyer Instruments
Detergent Dispenser	Wilden
Chemical Container Level Sensors	IFM
Exhaust Fan	Girton